MCDONNELL DOUGLAS

McDonnell Aircraft Company

RECEIVED

File 2/3 064C-2748 12 January 1993

JAN 15 1993

PRMT SECTION

Mr. Ed Saddler, Director Waste Management Program Missouri Department of Natural Resources P.O. Box 176 Jefferson City, Missouri 65102

RE: Hazardous Waste Storage Permit #0S0 062284 002, M0D000818963

Dear Mr. Saddler:

On 19 December 1992, integrity testing of the ramp station 1 and 2 4,380 gallon capacity underground storage tank was conducted. The test results indicated that the tank had a leak rate of 0.0563 gallons per hour. The tank, which was used for the storage of off specification jet fuel, was immediately placed out of service and will be replaced in 1993. Mr. Steve Jaques of the Waste Management Program was notified by telephone on 22 December 1992.

The amount of jet fuel released from the tank system is unknown. Previous integrity testing conducted on 08 June 1991 indicated a leak rate less that 0.05 gallons per hour. Ground water remediation in the area of the tank has been ongoing since 1991 under LU #2517 and 1519.

Please contact me should you need additional information.

Sincerely,

Jøe Haake, Group Manager

Environmental & Hazardous Materials Services

Dept. 064C/Mail Code 0343530

314-232-6941

JH:tb

cc: EPA RCRA Permits Section

Steve Jaques MDNR-SLRO, MMU

R00148122

RCRA RECORDS CENTER